



Environmental &  
Safety Professionals

A division of Enviro-Net Australia Pty. Ltd.  
ABN 39 067 499 389 ACN 067 499 389 NATA Reg. 3110  
Unit 2-2B Parker Street, Footscray, Victoria 3011  
Ph: (03) 9688 8000 Fax: (03) 9689 6470  
Email: [esp@esplabs.com.au](mailto:esp@esplabs.com.au)

Melbourne  
Sydney  
Newcastle

## CERTIFICATE OF AIR MONITORING

**DATE:** 14<sup>TH</sup> OCTOBER 2012

**ESP JOB NUMBER:** U1374

**NAME:** PROPERTY & CAMPUS SERVICES

**ADDRESS:** THE UNIVERSITY OF MELBOURNE  
625-631 SWANSTON STREET  
CARLTON VIC 3053

**ATTENTION:** ANNE THOMPSON

**SAMPLED FROM:** ARCHITECTURE (BN133) – GROUND FLOOR FOYER

**SAMPLED BY:** ESP – ENVIRONMENTAL & SAFETY PROFESSIONALS

**SAMPLED ON:** 14<sup>TH</sup> OCTOBER 2012

**TEST METHOD:** Filters examined in accordance with Guidance Note on the membrane Filter Method for Estimating Airborne Asbestos Fibres 2<sup>ND</sup> Edition [NOHSC:3003(2005)] using ESP in-house Method No. 1.

ESP NO.	LOCATION	RESULT (FIBRES/FIELD)	RESULT (FIBRES/mL)
<b><u>BOUNDARY AIR MONITORING DURING THE GROUND FLOOR CEILING INVESTIGATION</u></b> <b><u>REMOVALIST: CHAPMAN GARDNER (08:00 –14:10 HRS, 14/10/12)</u></b>			
24917	SOUTH EAST SIDE GROUND FLOOR FOYER	NIL / 100	<0.01
24918	SOUTH WEST SIDE GROUND FLOOR FOYER	NIL / 100	<0.01
24919	NORTH EAST SIDE GROUND FLOOR FOYER	2 / 100	<0.01
24920	NORTH WEST SIDE GROUND FLOOR FOYER	1 / 100	<0.01
24921	ADJACENT LIFT ENTRY GROUND FLOOR FOYER	NIL / 100	<0.01
24922	FIELD BLANK	NIL / 100	-

The results contained in this report relate only to the sample(s) submitted for testing.

**Darren Clerehan**  
Approved Counter / Approved Signatory



WORLD RECOGNISED  
ACCREDITATION

NATA Accredited Laboratory  
Number: 3110